



www.elsevier.com/locate/watres

EXAMINATION OF THE BEHAVIOUR OF ESCHERICHIA COLI IN BIOFILMS ESTABLISHED IN LABORATORY-SCALE UNITS RECEIVING CHLORINATED AND CHLORAMINATED WATER

MAGGY N. B. MOMBA1*, T. E. CLOETE2®, S. N. VENTER2® and R. KFIR3

¹Department of Biochemistry and Microbiology, University of Fort Hare, P/Bag x1314, Alice 5700, South Africa, ²Department of Microbiology and Plant Pathology, University of Pretoria, Pretoria 0002, South Africa and ³Technology Management, C.S.I.R., P.O. Box 395, Pretoria, South Africa

(First received May 1998; accepted in revised form December 1998)

Abstract—Groundwater was treated with chlorine and chloramine to study the incorporation and survival of *Escherichia coli* in developing biofilms in laboratory-scale units. Membrane filter and standard spread plate procedure were used to enumerate coliform and heterotrophic plate count bacteria respectively. Within 96 h the adhesion of heterotrophic plate count bacteria on stainless steel coupons was obvious in all systems, with a higher number of organisms (4 log cfu cm⁻²) noted for the non-disinfected water. Attachment of *E. coli* added 24 h after the formation of young biofilms was obvious on stainless steel coupons exposed to the non-disinfected water (9 cfu cm⁻²) and chlorinated water (2 cfu cm⁻²). A significant difference between *E. coli* counts in the non-disinfected water and chloraminated water, and the chlorinated and chloraminated water, was found. However, the ANOVA test indicated no significant difference in *E. coli* counts for the non-disinfected water and chlorinated water. This investigation revealed the effectiveness of chloramine in preventing the attachment of *E. coli* in developing biofilm. © 1999 Elsevier Science Ltd. All rights reserved

Key words-E. coli, biofilm, chlorinated water, chloraminated water

INTRODUCTION

The formation and presence of biofilms in drinking water distribution systems have been reported frequently (LeChevallier et al., 1987; van der Wende and Characklis, 1990; White et al., 1996). Biofilms developing in drinking water distribution system can lead to pronounced changes in microbial quality resulting in customer dissatisfaction with taste and odour, industrial user complaints on product deterioration and hospital concerns for patient exposure (Wierenga, 1985; Geldreich and Rice, 1987).

A large variety of different heterotrophic bacteria (including potentially pathogenic bacteria) have been isolated from the biofilm in distribution systems receiving both chlorinated and non-disinfected water (LeChevallier et al., 1987). The most alarming results are the presence and multiplication of pathogenic and opportunistic pathogens such as Escherichia coli, Pseudomonas, Klebsiella, Legionella spp and Mycobacter occurring within biofilms (Engel et al., 1980; Wadowsky et al., 1982; Burke et al., 1984). The increase in reported cases of coliform occurrence in chlorinated drinking water has been related to outbreaks of

E. coli has the important feature of being highly specific for the faeces of humans and warm-blooded animals. Generally E. coli fails to multiply in any natural water environment, and is, therefore, used as specific indicators for faecal pollution (Grabow, 1996; WHO, 1996). E. coli has been shown to be highly resistant to treatment process (Craun, 1991; Craun et al., 1994a). This form of resistance is often linked to the fact that a number of chemical and physical factors common to drinking water distribution systems are known to cause a form of sublethal and reversible injury during disinfection. These factors include chlorine and other biocides, low concentration of metals such as copper and zinc, extremes of temperature and pH and interactions with other bacteria (LeChevallier and McFeters, 1985). Several investigators have shown that coliforms could survive standard chlorine residuals with subsequent release into the distribution systems (McFeters et al., 1986). Attachment of bacteria to surfaces and specific growth conditions of bacterial cultures have also been shown to increase the chlorine resistance of bacteria. Ridgway and Olson (1982) showed high correlations between numbers of viable bacteria in chlorinated water and numbers of bacteria attached to particles. Research

waterborne diseases in the U.S. (Lippy and Waltrip, 1984).

^{*}Author to whom all correspondence should be addressed.

initiated by LeChevallier et al. (1987) indicated that coliforms in distribution systems originated from pipeline biofilms. Results showed that coliforms levels increased as the water moved from the treatment plant through the distribution systems. Computer modelling of hydraulic residence times showed that the increased coliform densities could not be accounted for by growth of the cells in the water column alone but must have come from biofilms in the distribution system. Results also showed that maintenance of 1-2 mg l⁻¹ free chlorine residual was insufficient to eliminate these occurrences of coliforms. However, a recent study performed by Momba et al. (1998) reported the effectiveness of monochloramine in controlling biofilm regrowth in laboratory-scale unit when comparing to chlorine, ozone and UV. This suggested that monochloramine could play an important role in the reduction or elimination of coliform bacteria within biofilms. These findings led to investigate the behaviour of coliform bacteria within biofilms.

Moreover, most studies on the survival of coliform bacteria in drinking water distribution systems have been done using surface water. No information is available to date on the situation pertaining to coliform bacteria in biofilm formed in groundwater distribution systems. However groundwater remains the main water supply source for many small communities in semi arid areas such as part of South Africa. In the past the general perception was that groundwater has self purification properties and has long been considered to be of excellent quality. Nevertheless, groundwater from shallow wells are frequently grossly polluted. Reports of some waterborne outbreaks and unsatisfactory coliform results in groundwater have led to the recommendation to disinfect many well waters and springs used for drinking water (Lippy and Waltrip, 1984; Craun, 1985). In recent years due to the realisation that groundwaters are the cause of waterborne disease outbreaks, many South Africa rural communities have adapted some measure of disinfection (chlorine) which often coincide with small scale water distribution or storage systems. Consequently, the study on the behavior of coliform in groundwater proved to be important.

In this study, groundwater was used to examine the incorporation and survival of *E. coli* developing biofilms in laboratory-scale units. chlorine and monochloramine were used as disinfectants.

MATERIAL AND METHODS

Biofilm apparatus

Three laboratory-scale units were used, one for each of the treatments and a separate unit for the control experiment (non-disinfected water). The unit consisted of 3×50 liter polyethylene drums which was used as a batch reactor. The batch reactor was attached to a peristaltic pump, which in turn was connected in series to a Pedersen device and a flow-through glass tube (Fig. 1). The purpose




Fig. 1. Schematic diagram of the laboratory-scale unit: (A) a sterile drum; (B), (C), (D), (E) latex tubing to allow water circulation; (F) a tap to allow sampling; (G) Pedersen device; (H) flow-through glass tube and (I) a peristaltic pump.

of a flow-through glass tube was for biofilm monitoring. The modified Pedersen device was used to allow biofilm formation to be studied. For this purpose, 20 stainless steel (316) coupons, the size of the microscope slide $(75 \times 25 \times 1 \text{ mm})$, were installed vertically into the Pedersen device and used for the enumeration of attached viable bacteria and *E. coli*.

Test organisms

E. coli ATCC 11775 was used in the experiment. The culture was stored on nutrient agar (Merck) at 4° C. When needed, 2 loops of E. coli were transferred into 100 ml nutrient broth (Merck) and aerobically cultured at 37° C for 24 h.

Source water and disinfection

Chlorine and monochloramine were used to disinfect groundwater collected from a well in a rural area. Concentrated solutions of the disinfectants were added to the water to provide a final free chlorine concentration of 2 mg I^{-1} and a 1.5 mg I^{-1} monochloramine concentration. The concentrations of free chlorine and monochloramine residuals were measured using the N,N-diethyl-p-phenylenediamine (DPD, Sigma) ferrous titrimetric method (APHA, 1989). No neutralization was done during the experimental period for any of the disinfectants used.

Biofilm formation

The non-disinfected water (control water) and the 2 disinfected waters were transferred into experimental distribution systems designed for the study of biofilm production. Water circulation was facilitated at a flow rate of $2.81\,h^{-1}$ and the experiments were conducted at room temperature. 24 h after circulation of raw water and disinfected water in different systems, *E. coli* was added to each systems to an initial concentration of $\pm 2.6 \times 10^4$ bacteria per liter. The experimental data is based on four replications of the study.

Sampling and microbial analyses

Stainless steel coupons were withdrawn 24 h (corresponding to 48 h in Table 1) after inoculation of *E. coli* and thereafter every day until the disinfectant concentrations had been completely eliminated in distribution systems (96 h). Attached bacteria were released from the stainless steel coupons by 2 min sonication (Bandelin Sonorex RK 255S) in 20 ml sterile MilliQ water. Attached heterotrophic bacteria were enumerated by the standard spread plate procedure using R2A agar (Difco), incubated at 28°C for 7 days (Reasoner and Geldreich, 1985).

E. coli in biofilms 2939

Table 1. Characteristic of the laboratory-scale units during the experimental study

Time	Residual disinfectants		
	chlorine (mg/l)	monochloramine (mg/l)	-
0	2	1.5	
24 h	0.7	0.8	
48 h	0.0	0.3	
72 h	0.0	0.0	
	non-disinfected water	chlorinated water	chloraminated water
Attached he	terotrophic plate count bacteria (a	verage cfu cm ⁻²)	
48 h	9.33×10^4	8.36×10^{3}	1.78×10^{2}
72 h	4.30×10^4	5.69×10^{3}	8.89×10^{2}
96 h	1.80×10^{4}	1.78×10^{3}	4.00×10^{2}
Attached E.	coli (average cfu cm ⁻²)		
48 h	9	2	0
72 h	3.32×10^{2}	4.8×10^{2}	0
96 h	1.88×10^{2}	2	0

Analyses were carried out in duplicate. *E. coli* were enumerated by the membrane filter procedure using a filter with a 0.45 μ m pore size (APHA, 1989). Membranes (Whatman) were placed on m-FC agar (Merck) and incubated for 24 ± 2 h at 44.5 ± 0.2 °C. Each determination was performed in triplicate.

Statistical analyses

To compare variation in treatments, ANOVA was applied to the bacterial counts with the latter as the dependent variable. The counts were transformed by taking logarithms base 10 (Lcount) to establish the variance. Times in hours from outset of the experimentation (24 h after the addition of initial *E. coli* density) were included as a co-variate. If significant factors (e.g. treatments) were found, then the least significant difference test (LSD) was applied to establish which particular levels of a factor are different, in terms of the bacterial counts.

RESULTS AND DISCUSSION

Although the systems had different initial concentrations of free chlorine (2 mg l⁻¹) and monochloramine (1.5 mg l^{-1}) , the treated waters contained approximately the same concentration of disinfectant residual (0.7 mg l⁻¹ for free chlorine and 0.8 mg l⁻¹ for monochloramine) after 24 h. Over a period of 24 h, residual levels decreased in the systems, and no residual was present in the chlorinated water after 48 h (Table 1). Monochloramine residual could be detected up to 48 h (0.3 mg l⁻¹) and was only depleted within 72 h. The persistence of monochloramine residual in potable water distribution systems was also found by others researchers (Mathieu et al., 1992), as well as during our study with bacterial regrowth or biofilm formation in potable surface water (Momba et al., 1998).

The adhesion of heterotrophic plate count bacteria on stainless steel coupons was noted during the study period of 96 h (Table 1). The ANOVA F-test showed a significant difference in heterotrophic plate count bacteria for the control (non-disinfected water), chlorinated and chloraminated water (ratio or $F_{(2,11)} = 22.49$, p < 0.00013). The least significance difference (LSD) also indicated a significant

difference between heterotrophic plate count bacteria in the non-disinfected water and chlorinated water (p < 0.00285), the non-disinfected water and chloraminated water (p < 0.00004), and the chlorinated and chloraminated water (p < 0.01542). Results of this experiment revealed the effectivess of monochloramine in controlling the growth of attached heterotrophic plate count bacteria in laboratory-scale unit within 96 h after disinfection.

While the attachment of E. coli in early biofilm formation was obvious in the non-disinfected water and chlorinated water distribution systems, no E. coli were detected on the stainless steel coupons exposed to the monochloramine treated water for the whole of the study period. The ANOVA F-test showed significant difference in E. coli counts for water treatments $(F_{2.17} = 7.10,$ p < 0.00577). The LSD test also indicated a significant difference in E. coli counts between non-disinfected water and chloraminated (p < 0.00320), and chlorinated and chloraminated water (p < 0.00706). However, the test indicated no significant difference in E. coli counts for the nondisinfected water and chlorinated water. These results showed the effectiveness of monochloramine in preventing the attachment of E. coli during early biofilm formation as well as the resistance of E. coli to chlorination and their attachment in young biofilms. This observation supported the findings of others showing the capability of coliform bacteria to survive high disinfectant doses of chlorine (Tracy et al., 1966; LeChevallier et al., 1988b). Previous investigators have shown that many coliforms survive standard chlorine residuals as chlorine-injured cells, with subsequent release in distribution systems (McFeters et al., 1986).

By the above analyses, there was abundant statistical evidence that monochloramine was effective not only in preventing the growth or attachment of *E. coli* during biofilm formation, but also in controlling the growth of attached heterotrophic bacteria.

Acknowledgements—The authors wish to thank Environmentek, Council for Scientific and Industrial Research (C.S.I.R.), Pretoria/South Africa, who sponsored this investigation and Mr. R. A. Agbadzi, Department of Statistics, University of Fort Hare, for his help in the statistic lay-out.

REFERENCES

- APHA (1989) Standard Methods for the Examination of Water and Wastewater, 17th edn. American Public Health Association, Washington, DC.
- Burke V., Robinson J., Gracey M., Peterson D. and Partridge K. (1984) Isolation of *Aeromonas hydrophila*, from a metropolitan water supply: seasonal correlation with clinical isolates. *Appl. Environ. Microbiol.* **48**, 361–366
- Craun G. F. (1985) Waterborne Disease in the United States. CRC Press, Boca Raton, FL, p. 295.
- Craun G. F. (1991) Causes of waterborne outbreaks in the U.S. *Water Sci. Technol.* **24**, 17–20.
- Craun G. F., Bull R. J., Clark R. M., Doull J., Grabow W., Marsh G. M., Okun D. A., Regli S., Sobsey M. D. and Symons J. M. (1994a) Balancing chemical and microbial risks of drinking water disinfection. Part I. Benefits and potential risks. *Aqua* 43b, 192–199.
- Engel H. W. B., Berwald L. G. and Havelaar A. H. (1980) The occurrence of *Mycobacterium kansasii* in tap water. *Tubercle* **61**, 21–26.
- Geldreich E. E. and Rice E. W. (1987) Occurrence, significance and detection of *Klebsiella* in water systems. *J. AWWA* **79**, 74–80.
- Grabow W. O. K. (1996) Waterborne diseases: update on water quality assessment and control. *Water SA* **22**(2), 193–201.
- LeChevallier M. W. and McFeters G. A. (1985) Interactions between heterotrophic plate count bacteria and coliforms organisms. *Appl. Environ. Microbiol.* 49, 1338–1341.
- LeChevallier M. W., Babcock T. M. and Lee R. G. (1987) Examination and characterization of distribution system biofilms. Appl. Environ. Microbiol. 53(12), 2714–2724.
- LeChevallier M. W., Cawthon C. D. and Lee R. G. (1988b) Mechanisms of bacterial survival in chlorinated drinking water. *Water Sci. Technol.* **20**(11–12), 145–151.

- Lippy E. C. and Waltrip S. C. (1984) Waterborne disease outbreaks 1946–1980: a thirty-five-year perspective. J. AWWA 76, 60–67.
- Mathieu L., Paquin J. L., Hartemann P. and Colin F. (1992) Paramètres controlant l'accumulation de bactéries dans les réseaux de distribution: approche expérimantale. Séminaire International. Matière organique biodégradable dans les réseaux de distribution. Nancy.
- McFeters G. A., Kippin J. J. and LeChevallier M. W. (1986) Injured coliforms in drinking water. Appl. Environ. Microbiol. 51, 1–5.
- Momba M. N. B., Cloete T. E., Venter S. N. and Kfir R. (1998) Evaluation of the impact of disinfection processes on the formation of biofilms in potable surface water distribution systems. *Water Sci. Technol.*, in press.
- Reasoner D. J. and Geldreich E. E. (1985) New medium for the enumeration and subculture of bacteria from potable water. *Appl. Environ. Microbiol.* **49**, 1–7.
- Ridgway H. F. and Olson B. H. (1982) Chlorine resistance pattern of bacteria from drinking water systems. *Appl. Environ. Microbiol.* 44, 972–987.
- Tracy H. W., Camarena V. M. and Wing F. (1966) Coliform persistence in highly chlorinated water. *J. AWWA* **58**, 1151–1159.
- van der Wende E. and Characklis W. G. (1990) Biofilms in potable water distribution systems. In *Drinking Water Microbiology: Progress and Recent Developments*, ed. G. A. McFeters, pp. 249–268. Springer-Verlag, New York.
- Wierenga J. T. (1985) Recovery of coliforms in the presence of the free chlorine residual. J. AWWA 42(9), 849.
- White D. C., Arrage A. A., Nivens D. E., Palmer R. J., Rice J. F. and Sayler G. S. (1996) On-line methods bring new insights into MIC and microbial biofouling. *Biofouling* **10**(1–3), 3–16.
- WHO (1996) Guidelines for Drinking-Water Quality, 2nd edn, Vol. 2. Health criteria and other supporting information. World Health Organization, Geneva, 973 pp.
- Wadowsky R. M., Yee R. B., Mezmar L., Wing E. J. and Dowling N. J. (1982) Hot water systems as sources of Legionella pneumophila in hospital and non-hospital plumbing fixtures. Appl. Environ. Microbiol. 43, 1104– 1110.